

---

# ***SUMMARY OF SUBMISSIONS (DECISIONS REQUESTED AND REASONS)***

## ***Agenda 2: Plan Change 2 - Transmission Lines***

---

<b><i>Ref</i></b>	<b><i>Relief Sought</i></b>
-------------------	-----------------------------

---

### ***Brittan, R G***

55.1 Retain the present requirement for a 20m setback but add this to Table 31.1. Add reference to NZECP 34:2001. The proposed Rule 23.1.1.9 is clear, but should be in Chapter 30.

*Reason* The District Plan should be clear and stand on its own. It should avoid reference to other documents where possible. The existing provision of a 20m setback is clear.

### ***Transpower New Zealand Limited***

56.1 Retain the plan change as notified with Rule 23.3.2 referring to Rule 23.1.1.9

*Reason* Transpower seeks to ensure that its assets within the Waimakariri District are sufficiently protected, that reverse sensitivity issues are avoided, and that public health and safety around high voltage transmission lines are maintained.

---

**Grand total**

2