

Appendix One – Submission Table

General Relief Sought
MainPower seeks the amendments to the Proposed Waimakariri District Plan as detailed in the table that follows, and including any alternate and/or consequential amendments to the issues, objectives, policies, rules, maps and other methods required to give effect to the relief sought.

Note: Proposed additions are underlined and deletions ~~strikethrough~~

Table 1 – Area Specific Matters – MRZ Medium Density Residential Zone

General Submission	Submission	Relief Sought
<u>Medium Density Residential Zone</u>	MainPower seeks to insert a new objective and policy to support the introduction of new corridor protection rules for electricity distribution lines operated by MainPower within the Medium Density Residential Zone.	<p>Insert the following new objective and policy:</p> <p><u>Objective:</u> <u>The operation and security of critical infrastructure, strategic infrastructure and regionally significant infrastructure is not compromised by other activities.</u></p> <p><u>Policy - Separation of incompatible activities</u></p> <p><u>Protect critical infrastructure, strategic infrastructure and regionally significant infrastructure by avoiding adverse effects, including reverse sensitivity effects, from incompatible activities by avoiding buildings, structures and any sensitive activities that may compromise the operation of Electricity Distribution Lines within an identified buffer corridor.</u></p>

General Submission	Submission	Relief Sought
<p>Medium Residential zone</p>	<p>MainPower seeks to insert corridor protection rules relating to Electricity Distribution Lines into the Medium Residential Zone chapter rules as lines are located within or immediately adjacent to that zone.</p> <p>Provisions relating to corridor protection for MainPower's Electricity Distribution Lines do not fall easily into the National Planning Standards framework because while they relate to infrastructure, they restrict land use activities and subdivision, and apply to specific zones.</p> <p>MainPower have a strong preference that corridor protection rules be located appropriately within the relevant zone chapters. From a usability perspective, it is most logical to include land use constraints associated with Electricity Distribution Lines in the applicable zone chapters where they are clearly visible to landowners who may check the plan to determine rules affecting their property.</p>	<p>Insert the following new rule:</p> <p><u>Earthworks adjacent to a major electricity distribution line</u></p> <p><u>Activity Status: PER</u></p> <p><u>Where:</u></p> <ol style="list-style-type: none"> <u>Earthworks shall be setback at least 6m from the centreline of the Major Electricity Distribution Line as shown on the planning maps or;</u> <u>Meet the following requirements:</u> <ol style="list-style-type: none"> <u>be no deeper than 300mm within 2.2m of the foundation of the major electricity distribution line support structure; and</u> <u>be no deeper than 0.75m between 2.2m and 6m from the foundation of the major electricity distribution line support structure; and</u> <u>earthworks shall not destabilise a major 66kV or 33kV electricity distribution line pole or tower; and</u> <p><u>Activity status when compliance not achieved: NC</u></p> <p><u>Notification</u></p> <p><u>An application for a non-complying activity under this rule is precluded from being publicly notified, but may be limited notified only to the relevant electricity distribution line operator where the consent authority considers this is required, absent its written approval.</u></p>

General Submission	Submission	Relief Sought
		<p data-bbox="1160 347 1608 699">d. earthworks shall not result in a reduction in the ground to conductor clearance distances below what is required by Table 4 in NZECP 34:2001 New Zealand Electricity Code of Practice for Electricity Safe Distances, unless the requirements of Clause 2.2.3 of NZECP 34:2001 New Zealand Electricity Code of Practice for Electricity Safe Distances are met.</p> <p data-bbox="1137 715 1281 738"><u>Exemptions</u></p> <p data-bbox="1137 786 1460 810"><u>This rule does not apply to:</u></p> <ul data-bbox="1187 858 2020 1249" style="list-style-type: none"> • <u>earthworks undertaken as part of agricultural or domestic cultivation; or repair, sealing or resealing of a road, footpath, driveway or vehicle access track;</u> • <u>earthworks that are undertaken by a network utility operator or their approved contractor on behalf of the network utility operator (other than for the reticulation and storage of water in canals, dams or reservoirs including for irrigation purposes);</u> • <u>earthworks for which prior written consent has been granted by the relevant electricity distribution line operator under the NZECP 34:2001 New Zealand Electricity Code of Practice for Electricity Safe Distances;</u> <p data-bbox="1137 1329 1326 1353"><u>Advisory Notes</u></p>

General Submission	Submission	Relief Sought
		<p>Insert the following new rule:</p> <p><u>Activities and development (other than earthworks or network utilities) adjacent to a major electricity distribution line</u></p> <p><u>Activity status: NC</u></p> <p><u>Where:</u></p> <ol style="list-style-type: none"> 1. <u>activities and development adjacent to a major electricity distribution line involve the following:</u> <ol style="list-style-type: none"> a. <u>new sensitive activity and new buildings within 6m of the centreline of a major electricity distribution line or within 6m of the foundation of a support structure; or</u> b. <u>complies with the requirements of NZECP34:2001.</u> <p><u>Notification</u></p> <p><u>An application under this rule is precluded from being publicly notified, but may be limited notified only to the relevant electricity distribution line operator where the consent authority considers this is required, absent its written approval.</u></p> <p><u>Advisory Notes</u></p> <p><u>Activity status when compliance not achieved: N/A</u></p>

General Submission	Submission	Relief Sought		
		<div><ul style="list-style-type: none">Major electricity distribution lines are shown on the planning map.Vegetation to be planted around electricity distribution lines should be selected and managed to ensure that it will not breach the Electricity (Hazards from Trees) Regulations 2003.The NZECP 34:2001 New Zealand Electricity Code of Practice for Electricity Safe Distances contains restrictions on the location of activities and development in relation to electricity distribution lines. Activities and development in the vicinity of these lines must comply with NZECP 34:2001 New Zealand Electricity Code of Practice for Electricity Safe Distances.</div> <div>Insert the following new rule:</div> <table><tr><td><div><div>Structures near a major electricity distribution line</div><div>Activity status: NC</div><div><div><div>1. The establishment of a new, or expansion of an existing structure:</div><div>Where:</div><div>2. The structure is within 6m of the centreline of a major electricity distribution line as shown on the planning maps; or</div><div>3. The structure is within 6m of the foundation of a support structure of a major electricity distribution line as shown on the planning maps, or</div></div></div></div></td><td><div>Activity status when compliance not achieved: NC</div></td></tr></table>	<div><div>Structures near a major electricity distribution line</div><div>Activity status: NC</div><div><div><div>1. The establishment of a new, or expansion of an existing structure:</div><div>Where:</div><div>2. The structure is within 6m of the centreline of a major electricity distribution line as shown on the planning maps; or</div><div>3. The structure is within 6m of the foundation of a support structure of a major electricity distribution line as shown on the planning maps, or</div></div></div></div>	<div>Activity status when compliance not achieved: NC</div>
<div><div>Structures near a major electricity distribution line</div><div>Activity status: NC</div><div><div><div>1. The establishment of a new, or expansion of an existing structure:</div><div>Where:</div><div>2. The structure is within 6m of the centreline of a major electricity distribution line as shown on the planning maps; or</div><div>3. The structure is within 6m of the foundation of a support structure of a major electricity distribution line as shown on the planning maps, or</div></div></div></div>	<div>Activity status when compliance not achieved: NC</div>			

General Submission	Submission	Relief Sought
		<p data-bbox="1144 309 1765 376">4. <u>Complies with the requirements of NZECP34:2001</u></p> <p data-bbox="1095 419 1240 448"><u>Notification</u></p> <p data-bbox="1095 454 1765 625"><u>An application under this rule is precluded from being publicly notified, but may be limited notified only to the relevant electricity distribution line operator where the consent authority considers this is required, absent its written approval.</u></p>